



NOTES:

1. EACH SECTION OF PIPE WITHIN CASING SHALL HAVE A MINIMUM OF (3) CASING SPACERS/SKIDS. THE MIDDLE SPACER/SKID SHALL BE CENTERED BETWEEN PIPE JOINTS.
2. EACH PIPE JOINT SHALL BE RESTRAINED.
3. IF THE 10-POINT SOILS TEST EVALUATION CONCLUDES SOIL CORROSION AND THE NACE RECOMMENDATION REQUIRES SACRIFICIAL ANODES, AS INDICATED ON PLANS.
4. EXTEND TRACING WIRE THROUGH CASING (WATER APPLICATIONS ONLY).
5. SEE ADDITIONAL CATHODIC PROTECTION INFORMATION ON STD DWG W-105.

STEEL CASING DRAWING



CITY OF LOVELAND
DEPARTMENT OF
WATER AND POWER

W/WW CONSTRUCTION
DRAWINGS

DATE APPROVED:	08/07
DATE REVISED:	2019
10TH EDITION	

DRAWING
W-104